

Mains Design Instruction

Underground distribution cables – continuous current rating

IMPORTANT DISCLAIMER

As the information contained in this publication is subject to change from time to time, Endeavour Energy gives no warranty that the information is correct or complete or is a definitive statement of procedures. Endeavour Energy reserves the right to vary the content of this publication as and when required. You should make independent inquiries to satisfy yourself as to correctness and currency of the content. Endeavour Energy expressly disclaims all and any liability to any persons whatsoever in respect of anything done or not done by any such person in reliance, whether in whole or in part, on this document.

Mains Design Instruction

ASSET STANDARDS & DESIGN

Document No	:	MDI 0011
Amendment No	:	6
Approved By	:	MSAD
Approval Date	:	06/07/2016
Review Date	:	06/07/2019

MDI 0011 UNDERGROUND DISTRIBUTION CABLES – CONTINUOUS CURRENT RATING

CONTENTS

1.0	PURPOSE.....	3
2.0	SCOPE	3
3.0	REFERENCES.....	3
4.0	DEFINITIONS AND ABBREVIATIONS.....	3
5.0	ACTIONS.....	3
5.1	Current ratings	3
5.2	Installation conditions	4
5.3	Continuous current rating tables	4
5.3.1	<i>Low voltage cables</i>	5
5.3.2	<i>High voltage cables</i>	6
6.0	AUTHORITIES AND RESPONSIBILITIES.....	9
7.0	DOCUMENT CONTROL	9
	Annexure 1: Rating factors – Winter temperature	10
	Annexure 2: Rating factors – Soil thermal resistivity	11
	Annexure 3: Rating factors – Cable depth	12
	Annexure 4: Rating factors – Cable formation.....	13
	Annexure 5: Rating factors – Proximity to other multicore cables	15
	Annexure 6: Examples applying multiple rating factors	17

1.0 PURPOSE

To specify the continuous current ratings of underground distribution cables that are installed on Endeavour Energy's underground distribution cable network.

2.0 SCOPE

The continuous current ratings covered by this instruction are considered to be conservative and will be adequate for all normal operating conditions.

3.0 REFERENCES

Internal

- Company Policy 9.2.10 – Network asset ratings
- Annexure 1: Rating factors – Winter temperature
- Annexure 2: Rating factors – Soil thermal resistivity
- Annexure 3: Rating factors – Cable depth
- Annexure 4: Rating factors – Cable formation
- Annexure 5: Rating factors – Proximity to other multicore cables
- Annexure 6: Examples applying multiple rating factors

External

- ENA National Electricity Network Safety Code (Doc 01-2008)
- AS/NZS 3008.1.1:2009 - Electrical installations - Selection of cables
- AS/NZS 4026:2001 - Electric cables for underground residential distribution
- IEC 60287-3-1:1995 - Electric cables - Calculation of the current ratings

4.0 DEFINITIONS AND ABBREVIATIONS

ASP	Accredited Service Provider
ETS	Equipment Technical Specification
HDPE	High Density Polyethylene Cable
HV	High Voltage – a voltage exceeding 1,000 volts alternating current
LV	Low Voltage – a voltage normally exceeding 50 volts alternating current (AC), but not normally exceeding 1,000 volts AC.
TR-XLPE	Tree-Retardant Cross Linked Polyethylene
XLPE	Cross Linked Polyethylene - the primary insulation of the cable. For the purposes of this document, cables with XLPE insulation also refer to cables with TR-XLPE and X-90 insulation.

5.0 ACTIONS

The electrical loadings applied to distribution underground cables must be in accordance with this instruction.

5.1 Current ratings

The tables listed in Section 5.3 give continuous current ratings for the most common installation conditions, as outlined in Section 5.2. These ratings should be used unless more specific information is available on the installation. If the installation conditions vary from those outlined in Section 5.2, the rating factors in the annexures must be applied to cater for changes to;

- Winter soil temperatures (Annexure 1);
- Soil thermal resistivity (Annexure 2);
- Cable depth (Annexure 3);

- Cable formation (Annexure 4); and/or
- Proximity to other cable installations (Annexure 5).

The rating for the single core cables assumes only one cable is being used per phase and is installed in trefoil.

If cables of different voltages are installed in the trench, the most conservative rating factor should be applied to all of the cables in the trench. An example is provided in Annexure 6, Example 4. A less conservative rating factor may only be applied if a cable rating study is conducted.

The cable rating must be limited by the section in the cable route that has the most significant impact on the cable rating. Even short distances where the cable enters thermally unfavourable conditions, such as a short cable section of increased depth, must be considered and cannot be ignored unless a rating study has proven there to be minimal impact on the cable rating.

Where a cable is proposed to cross over or under another cable circuit, the operating temperature of the cables can reduce the rating of both circuits. In addition, the installation scenarios and rating factors given in this standard may not be adequate to cover complex cable arrangements, such as within zone substations. A cable rating study should be conducted to calculate the applicable cable rating based on the installation conditions.

Where a rating study is required for an internal project, Transmission Mains Development is responsible for calculating a suitable cable rating. Where a rating study is required for a contestable (external) project, the Level 3 ASP Designer is responsible for calculating a suitable cable rating and must be checked by Transmission Mains Development.

For emergency ratings of the cables, contact the Network Mains Manager.

For short circuit and earth fault ratings of the new cables, refer to respective ETS.

5.2 Installation conditions

Table 1: Installation conditions for a LV and HV cable (direct buried or in a conduits).

Voltage	Laying depth (m)	Cable insulation/ construction	Maximum continuous conductor temperature (°C)	Soil Thermal resistivity (°Cm/W)	Soil temperature (°C)
LV	0.6	XLPE	90	1.2	25
		Paper	80		
HV	0.8	XLPE, screened	90		
		Paper, belted	65		
		Paper, screened	70		

The soil thermal resistivity and soil temperatures are in accordance with Company Policy 9.2.10.

5.3 Continuous current rating tables

The continuous current ratings given in the tables below are the maximum ratings to be applied.

5.3.1 Low voltage cables

Table 2: XLPE insulated low voltage cables

Conductor material	Number of cores	Cable core cross sectional area	Continuous summer rating (Amps)	
			Buried in duct	Buried direct
Copper	1	16 mm ²	105	140
		25 mm ²	135	180
	2	16 mm ²	100	130
	4	16 mm ²	80	110
		25 mm ²	110	145
		50 mm ²	160	205
Aluminium		150 mm ²	240	330
		185 mm ²	280	340
	240 mm ²	330	395	

Table 3: Paper insulated low voltage cables

Conductor material	Number of cores	Cable core cross sectional area	Continuous summer rating (Amps)	
			Buried in duct	Buried direct
Copper	3.5	0.1 inch ²	175	215
		0.15 inch ²	215	255
		0.2 inch ²	255	310
		0.3 inch ²	325	400
		0.4 inch ²	385	465
Aluminium	3.5	0.1 inch ²	135	165
		0.2 inch ²	200	245
		0.4 inch ²	300	370
		240 mm ²	295	350

Table 4: Consac low voltage cables

Conductor material	Cable core cross sectional area	Continuous summer rating (Amps)	
		Buried in duct	Buried direct
Aluminium	0.06 inch ²	100	120
	0.1 inch ²	140	170
	0.15 inch ²	170	205

Conductor material	Cable core cross sectional area	Continuous summer rating (Amps)	
		Buried in duct	Buried direct
	0.2 inch ²	205	245
	0.25 inch ²	235	270
	0.3 inch ²	265	320
	0.4 inch ²	310	370
	95 mm ²	170	205
	185 mm ²	250	300
	240 mm ²	295	355

5.3.2 High voltage cables

Table 5: 11kV XLPE insulated cables

Number of cores	Conductor material	Cable core cross sectional area	Continuous summer rating (Amps)	
			Buried in duct	Buried direct
1	Copper	25 mm ²	122	145
		70 mm ²	220	249
		150 mm ²	325	370
		185 mm ²	360	415
		240 mm ²	410	480
		500 mm ²	550	660
	Aluminium	50 mm ²	155	160
		150 mm ²	260	290
		185 mm ²	290	330
		240 mm ²	335	380
		500 mm ²	470	550
3	Copper	185 mm ²	360	425
		240 mm ²	420	500
		300 mm ²	475	560
		500 mm ²	587	678
	Aluminium	35 mm ²	105	125
		95 mm ²	190	220
		185 mm ²	275	320
		240 mm ²	320	370
		300 mm ²	365	429

Table 6: 11kV paper insulated cables

Cable construction (number of cores)	Conductor material	Cable core cross sectional area	Continuous summer rating (Amps)	
			<i>Buried in duct</i>	<i>Buried direct</i>
Lead sheath, armoured, screened (3 core)	Copper	150 mm ²	255	305
		185 mm ²	295	340
		300 mm ²	380	435
		0.1 inch ²	170	195
		0.25 inch ²	275	320
		0.3 inch ²	305	355
		0.5 inch ²	400	455
	Aluminium	120 mm ²	175	205
		150 mm ²	205	240
		240 mm ²	265	310
		300 mm ²	300	350
		0.15 inch ²	160	195
		0.3 inch ²	240	280
		0.5 inch ²	315	355
		0.75 inch ²	370	430
Lead sheath, HDPE served, screened (3 core)	Aluminium	240 mm ²	265	310
		300 mm ²	300	350
Lead sheath, PVC served, screened (1 core)	Copper	185 mm ²	300	345
		0.5 inch ²	400	460
		0.75 inch ²	480	570
Lead sheath, armoured, belted (3 core)	Copper	50 mm ²	125	145
		185 mm ²	265	315
		240 mm ²	315	365
		300 mm ²	350	410
		0.04 inch ²	85	100
		0.06 inch ²	110	130
		0.1 inch ²	155	180
		0.15 inch ²	190	225
		0.2 inch ²	225	260
		0.3 inch ²	295	335
		0.5 inch ²	375	430
	Aluminium	95 mm ²	140	170
		150 mm ²	185	220
		185 mm ²	210	250
		240 mm ²	250	290
		300 mm ²	280	325

Cable construction (number of cores)	Conductor material	Cable core cross sectional area	Continuous summer rating (Amps)	
			<i>Buried in duct</i>	<i>Buried direct</i>
		0.15 inch ²	150	175
		0.2 inch ²	175	205
		0.3 inch ²	235	265
		0.4 inch ²	270	310
		0.5 inch ²	300	340

Table 7: 22kV XLPE insulated cables

Number of cores	Conductor material	Cable core cross sectional area	Continuous summer rating (Amps)	
			<i>Buried in duct</i>	<i>Buried direct</i>
1	Copper	70 mm ²	221	248
3	Copper	240 mm ²	425	500
	Aluminium	150 mm ²	250	295
		240 mm ²	320	365
		300 mm ²	375	435

6.0 AUTHORITIES AND RESPONSIBILITIES

General Manager Asset Management has the authority and responsibility for approving this instruction.

Manager Asset Standards & Design has the authority and responsibility for:

- reviewing and updating this instruction in accordance with Company Policy and Procedures; and
- endorsing and recommending changes and revision to this instruction.

Network Mains Manager has the authority and responsibility for:

- determining the emergency/short circuit current ratings of all underground cables used on the Endeavour Energy electrical network;
- endorsing and recommending changes and revisions to this instruction; and
- endorsing variations from the requirements of this instruction.

Transmission Mains Development Manager has the authority and responsibility for:

- determining the continuous current ratings (rating study) of underground cables installed within a zone substation;
- determining the continuous current ratings (rating study) of underground cables for internal projects that do not satisfy the assumptions or requirements of this standard; and
- checking the continuous current rating calculations (rating study) of underground cables by Level 3 ASP Designers for external projects that do not satisfy the assumptions or requirements of this standard.

Manager System Control has the authority and responsibility for overseeing System Operations employees comply with the requirements of this instruction.

Regional Managers have the authority and responsibility for overseeing that all designs carried out by Regional employees conform to the requirements of this instruction.

Manager Network Connections has the authority and responsibility for overseeing that all designs submitted by Level 3 ASP Designers conform to the requirements of this instruction.

Level 3 ASP Designers have the responsibility for calculating the continuous current rating calculations (rating study) of underground cables that do not satisfy the assumptions or requirements of this standard.

7.0 DOCUMENT CONTROL

Documentation Content Coordinator : Network Mains Manager

Documentation Distribution Coordinator : Branch Process Coordinator

Annexure 1: Rating factors – Winter temperature**A1.1 Rating factor for variation of soil temperature from 25°C**

Table 8: Rating factors for winter ambient soil temperature


Cable insulation/construction	Maximum Conductor temperature for continuous (°C)	Soil ambient temperature (°C)	
		25°C (Summer)	18°C (Winter)
HV or LV XLPE	90	1.00	1.06
LV paper insulated	80	1.00	1.07
HV paper insulated, screened	70	1.00	1.09
HV paper insulated, belted	65	1.00	1.10

Annexure 2: Rating factors – Soil thermal resistivity**A2.1. Rating factor for variation of soil thermal resistivity from 1.2°Cm/W****Table 9: Rating factors for multicore cables direct buried**

Conductor size (mm ²)	Soil thermal resistivity (°Cm/W)						
	0.8	0.9	1.0	1.5	2.0	2.5	3.0
Up to 16	1.09	1.06	1.04	0.95	0.86	0.79	0.74
From 25 to 150	1.14	1.10	1.07	0.92	0.82	0.74	0.68
From 185 to 400	1.16	1.11	1.07	0.92	0.82	0.74	0.68

Table 10: Rating factors for multicore cables laid in duct/s


Conductor size (mm ²)	Soil thermal resistivity (°Cm/W)						
	0.8	0.9	1.0	1.5	2.0	2.5	3.0
Up to 16	1.05	1.04	1.03	0.97	0.92	0.87	0.83
From 25 to 150	1.07	1.05	1.03	0.96	0.90	0.85	0.78
From 185 to 400	1.09	1.06	1.04	0.95	0.87	0.82	0.76

Annexure 3: Rating factors – Cable depth**A3.1. Rating factor for depth of laying****Figure 1: Illustration of the depth D which is to be taken from the ground surface to the centre of the cable.****Table 11: Rating factors for multicore cables direct buried**

Depth of laying D (m)	LV multicore cables			HV multicore cables	
	Up to 50mm ²	70mm ² to 300mm ²	Above 300mm ²	Up to 300mm ²	Above 300mm ²
0.6	1.00	1.00	1.00	-	-
0.8	0.98	0.98	0.97	1.00	1.00
1.00	0.96	0.96	0.95	0.98	0.97
1.25	0.95	0.94	0.93	0.96	0.95
1.50	0.94	0.93	0.92	0.95	0.94
1.75	0.93	0.91	0.90	0.94	0.92
2.00	0.92	0.90	0.89	0.92	0.90
2.50	0.91	0.89	0.88	0.91	0.89
3.0 or more	0.90	0.88	0.86	0.90	0.88

Table 12: Rating factors for cables laid in duct/s

Depth of laying D (m)	LV cables		HV cables	
	Single core	Multicore	Single core	Multicore
0.6	1.00	1.00	-	-
0.8	0.97	0.98	1.00	1.00
1.00	0.95	0.97	0.98	0.99
1.25	0.92	0.96	0.95	0.97
1.50	0.91	0.95	0.93	0.96
1.75	0.90	0.95	0.92	0.95
2.00	0.89	0.94	0.90	0.94
2.50	0.88	0.94	0.89	0.93
3.0 or more	0.87	0.93	0.88	0.92

Annexure 4: Rating factors – Cable formation**A4.1. Rating factor for groups of multicore cables in horizontal formation****Figure 2: Illustration of ducts laid in horizontal formation.****Table 13: Rating factors for multicore cables direct buried**

Cable voltage kV	Number of cables in group	Proximity rating factors
		Cables Touching
0.6/1kV	2	0.81
	3	0.70
	4	0.63
	5	0.59
	6	0.55
11kV 22kV	2	0.80
	3	0.69
	4	0.63
	5	0.57
	6	0.55

Table 14: Rating factors for multicore laid in ducts

Cable voltage kV	Number of cables in group	Proximity rating factors
		Ducts touching
0.6/1kV	2	0.90
	3	0.82
	4	0.78
	5	0.75
	6	0.72
11kV and 22kV	2	0.88
	3	0.80
	4	0.75
	5	0.71
	6	0.69

A4.2. Rating factor for multicore cables laid in duct in tier formation

The following can be used for XLPE, TR-XLPE and paper insulated cables.




Figure 3: Illustration of ducts laid in tier formation.

Table 15: Rating factors for LV insulated multi-core cables

Spacing (mm)	Proximity rating factors					
	3 ducts	4 ducts	6 ducts	8 ducts	9 ducts	12 ducts*
0 (touching)	0.82	0.77	0.68	0.62	0.59	0.54
50	0.83	0.78	0.69	0.63	0.60	0.55

Table 16: Rating factors for HV insulated multi-core cables

Spacing (mm)	Proximity rating factors					
	3 ducts	4 ducts	6 ducts	8 ducts	9 ducts	12 ducts*
0 (touching)	0.8	0.74	0.65	0.59	0.56	0.51
50	0.81	0.75	0.66	0.60	0.57	0.52

* This applies for both 4 x 3 and 3 x 4 arrangements.

A4.3. Rating factor for installation by underbore or horizontal directional drilling

Table 17: Rating factors for cables in underbores.

Cable Type	Underbore installation type		
	Un-sleeved	Sleeved and grouted* borehole	Sleeved and un-grouted borehole
(example)			
Single core	1.00	1.00	0.93
Multi-core	1.00	1.00	0.96

* Grout refers to any thermally rated duct fill material, recognised as having thermal resistivity less than or equal to 1.2°Cm/W.

Annexure 5: Rating factors – Proximity to other multicore cables

A5.1. Proximity rating factor for the separation of two banks of ducts

This section should be used with Annexure 4: Rating factors – Cable formation to obtain the applicable cable rating.




Figure 4: Illustration of distance L between 2 banks of ducts.

Table 18: Rating factors for distance between 2 banks with various ducts in each.

Distance L (m)	Proximity rating factors				
	2 ducts	3 ducts	4 ducts	5 ducts	6 ducts
1	0.89	0.88	0.85	0.83	0.83
2	0.93	0.93	0.91	0.91	0.91
3	0.95	0.94	0.93	0.93	0.93
4	0.97	0.96	0.95	0.95	0.95
5	0.98	0.97	0.96	0.96	0.96
6	0.99	0.97	0.97	0.97	0.97
7	0.99	0.97	0.97	0.97	0.97
8	0.99	0.98	0.97	0.97	0.97
10	1	0.99	0.98	0.98	0.98
12	1	0.99	0.98	0.98	0.98
≥ 15	1	1	1	1	1

If the two duct banks have a different number of ducts in each, the average rating should be used, e.g. if the number of ducts in each bank was 3 and 6, the rating should be taken as the average between two banks with 3 ducts in each and two banks with 6 ducts in each. An example is provided in Annexure 6, Example 3.

A5.2. Proximity rating factor for the separation of single ducts




Figure 5: Illustration of distance L between single ducts (shown with 5 or 6 ducts).

Table 19: Rating factors for distance between 5 or 6 banks with 1 duct in each.

Distance L (m)	Proximity rating factor	
	5 ducts	6 ducts
0.5	0.79	0.77
0.75	0.84	0.83
1	0.88	0.87
1.25	0.9	0.9
1.5	0.93	0.92
3	0.98	0.97
4	0.99	0.98
6	0.99	0.99
≥ 8	1	1

Annexure 6: Examples applying multiple rating factors

Example 1: Cables installed in a bank of 6 ducts

A bank of 6 ducts has been installed. It has been forecasted that 4 x 3C 240mm² copper 11kV XLPE are required and is proposed to be installed as shown in Figure 6. The soil thermal resistivity is 1.2°Cm/W.




Figure 6: 4 x 3C 240mm² copper 11kV XLPE cables installed in ducts. Two of the ducts are not being used in foreseeable future.

The rating for a 3C 240mm² copper 11kV XLPE cable installed in a duct is listed in Table 5 as 420A. This rating must be adjusted using the rating factors applicable to the installation details.

As only 4 cables are required in the foreseeable future, the cable rating can assume the conduit bank is in a 2 x 2 arrangement, i.e. the spare conduits can be ignored. If the spare conduits are used in the future, the cable ratings will need to be adjusted to include the 2 additional cables.

Installation conditions	Reference	Rating Factor
Summer rating	Annexure 1 Table 8	1
1.2°Cm/W thermal resistivity	Annexure 2 Table 10	1
2m HV multicore cable depth	Annexure 3 Table 12	0.94
2 x 2 HV cable duct formation with 50mm separation	Annexure 4 Table 16	0.75
Not installed near other cable installations	Annexure 5	1

A summary of the rating factors are listed above and can be used to calculate the overall rating factor;

$$\text{Overall rating factor} = 1 \times 1 \times 0.94 \times 0.75 \times 1 \\ = 0.705$$

This can now be used with the cable rating to find the feeder rating under the installation conditions;

$$\text{Feeder ratings} = 420A \times 0.705 \\ = 296A$$

Example 2: Cables installed in 2 banks of 2 ducts

2 banks of 2 ducts have been installed with a 3C 300mm² aluminium 22kV XLPE cable in each duct, as shown in Figure 7. The soil thermal resistivity is 1.2°Cm/W.




Figure 7: 3C 300mm² aluminium 22kV XLPE cables installed in 2 banks of 2 ducts.

The rating for a 3C 300mm² aluminium 22kV XLPE cable installed in a duct is listed in Table 7 as 375A. This rating must be adjusted using the rating factors applicable to the installation details.

Installation conditions	Reference	Rating Factor
Summer rating	Annexure 1 Table 8	1
1.2°Cm/W thermal resistivity	Annexure 2 Table 10	1
2m HV multicore cable depth	Annexure 3 Table 12	0.94
2 HV cable duct formation with ducts touching	Annexure 4 Table 14	0.88
1.5m separation between banks of 2 ducts.	Annexure 5 Table 18	1m separation=0.89 2m separation=0.93

A summary of the rating factors are listed above and can be used to calculate the overall rating factor. However, Annexure 5 Table 18 does not provide a rating factor for 2 banks of conduits with a 1.5m separation. Instead, an average of the rating factors for 1m and 2m separation can be used;

$$\text{Rating factor for 2 banks with 1.5m separation} = \frac{0.89 + 0.93}{2} = 0.91$$

Therefore;

$$\text{Overall rating factor} = 1 \times 1 \times 0.94 \times 0.88 \times 0.91 = 0.753$$

This can now be used with the cable rating to find the feeder rating under the installation conditions;

$$\text{Feeder ratings} = 375A \times 0.753 = 282A$$

Example 3: Cables installed in 2 banks with 4 and 2 ducts

2 banks with 4 and 2 ducts have been installed with a 3C 300mm² aluminium 22kV XLPE cable in each duct, as shown in Figure 8. The soil thermal resistivity is 1.2°Cm/W.




Figure 8: 3C 300mm² aluminium 22kV XLPE cables installed in 2 banks with 4 and 2 ducts.

The rating for a 3C 300mm² aluminium 22kV XLPE cable installed in a duct is listed in Table 7 as 375A. This rating must be adjusted using the rating factors applicable to the installation details.

The sections in Annexure 5 do not list the rating factors for installations where there the banks have a different number of ducts installed. As the cables are the same in all ducts, an average of the rating factors can be calculated and used.

Firstly, assume both banks contain only 2 ducts in each. The subsequent rating factors are outlined below.

Installation conditions	Reference	Rating Factor
Summer rating	Annexure 1 Table 8	1
1.2°Cm/W thermal resistivity	Annexure 2 Table 10	1
2m HV multicore cable depth	Annexure 3 Table 12	0.94
2 HV cable duct formation with ducts touching	Annexure 4 Table 14	0.88
2m separation between banks of 2 ducts.	Annexure 5 Table 18	0.93

$$\text{Rating factor for 2 banks of 2 ducts} = 1 \times 1 \times 0.94 \times 0.88 \times 0.93 = 0.769$$

Secondly, assume both banks contain 4 ducts in each. The subsequent rating factors are outlined below.

Installation conditions	Reference	Rating Factor
Summer rating	Annexure 1 Table 8	1
1.2°Cm/W thermal resistivity	Annexure 2 Table 10	1
2m HV multicore cable depth	Annexure 3 Table 12	0.94
4 HV cable duct formation with ducts touching	Annexure 4 Table 14	0.74
2m separation between banks of 4 ducts.	Annexure 5 Table 18	0.91

$$\text{Rating factor for 2 banks of 4 ducts} = 1 \times 1 \times 0.94 \times 0.74 \times 0.91 = 0.633$$

Therefore;

$$\text{Overall rating factor} = \frac{0.769 + 0.633}{2} = 0.701$$

This can now be used with the cable rating to find the feeder rating under the installation conditions;

$$\text{Feeder ratings} = 375A \times 0.701 = 262A$$

Example 4: LV and HV cables in the same cable trench

6 ducts have been installed with a 3C 240mm² copper 11kV XLPE cable in 3 ducts and a 4C 240mm² aluminium 1kV XLPE cable in the other 3 ducts, as shown in Figure 9. The soil thermal resistivity is 1.2°Cm/W.




Figure 9: 3C 240mm² copper 11kV XLPE cable in 3 ducts and a 4C 240mm² aluminium 1kV XLPE cable in the other 3 ducts.

The rating for a 3C 240mm² copper 11kV XLPE cable installed in a duct is listed in 4 as 320A. The rating for a 4C 240mm² aluminium 1kV XLPE cable installed in a duct is listed in 1 as 330A. These ratings must be adjusted using the rating factors applicable to the installation details.

Since there are cables of different voltages in the same trench, the worst case rating factor must be applied to all cables in the trench. To do so, first assume all of the ducts are installed with LV cables. The rating factors have been summarised below.

Installation conditions	Reference	Rating Factor
Summer rating	Annexure 1 Table 8	1
1.2°Cm/W thermal resistivity	Annexure 2 Table 10	1
1.5m LV multicore cable depth	Annexure 3 Table 12	0.95
3 x 2 LV cable duct formation with 50mm separation	Annexure 4 Table 15	0.69
Not installed near other cable installations	Annexure 5	1

$$\text{Rating factor for 6 LV cables} = 1 \times 1 \times 0.95 \times 0.69 \times 1 \\ = 0.656$$

Now assume all of the ducts are installed with HV cables. The rating factors have been summarised below.

Installation conditions	Reference	Rating Factor
Summer rating	Annexure 1 Table 8	1
1.2°Cm/W thermal resistivity	Annexure 2 Table 10	1
1.5m HV multicore cable depth	Annexure 3 Table 12	0.96
3 x 2 HV cable duct formation with 50mm separation	Annexure 4 Table 16	0.66
Not installed near other cable installations	Annexure 5	1

$$\text{Rating factor for 6 HV cables} = 1 \times 1 \times 0.96 \times 0.66 \times 1 \\ = 0.634$$

The most conservative rating factor is for 6 HV cables being installed and should therefore also be applied to the LV cables;

$$\text{HV feeder ratings} = 320\text{A} \times 0.634 \\ = \mathbf{202\text{A}}$$

$$\text{LV feeder ratings} = 330\text{A} \times 0.634 \\ = \mathbf{209\text{A}}$$